

NOTIFICATION OF ENVIRONMENTAL CONCERN (NEC) INVESTIGATION REPORT

GENERAL INFORMATION

NOTIFICATION NUMBER 010721-KM-1036				<input checked="" type="checkbox"/> PCS	<input type="checkbox"/> IWM	NDEQ ID #47321
INSPECTOR Mark Henning						
INSPECTION DATE Called Wayne WWTF on 1/7/21 and 1/8/21 Called the complainant on 1/12/21	TIME/ARRIVAL N/A	TIME/DEPARTURE N/A	WEATHER N/A			TEMP N/A

PROBLEM LOCATION Same as NEC Problem Location

NAME Wayne WWTF					PROGRAM ID # NE0033111
POSITION/TITLE					
BUSINESS NAME Wayne WWTF					
ADDRESS 400 Dearborn St.	CITY Wayne	COUNTY Wayne	STATE NE	ZIP CODE 68787	
QUARTER	SECTION 18	TOWNSHIP 26	RANGE E 04		
DIRECTIONS TO SITE Go east on east 4 th st. turn south on Dearborn on left hand side of the street.		LATITUDE 42° 13' 53"	LONGITUDE 97° 38"		

RESPONSIBLE PARTY Same as NEC Responsible Party

NAME Wayne WWTF					PROGRAM ID #
POSITION/TITLE					
BUSINESS NAME					
ADDRESS	CITY	COUNTY	STATE NE	ZIP CODE	
TELEPHONE NUMBER (H) 402-375-5250	TELEPHONE NUMBER (W) 402-375-5250	TELEPHONE NUMBER (C)		EMAIL betty@cityofwayne.org	

SITE OBSERVATIONS

WHAT IS THE PROBLEM? Same as NEC Observations

COMMENTS


- I called the Wayne Wastewater Treatment plant on January 7, 2012 and left a message. I called them back on January 8, 2021 and reached Casey discussed with him that there was a complaint of odors from around the end of August to the first part of September and asked if there had been anything that happened with the treatment plant in that time frame. Casey stated that the final drive went out on one of the clarifiers and that they had to reroute the wastewater back into the headworks. There are two final clarifiers so the system was still able to operate but there was an increase in odors at that



WHAT IS THE PROBLEM?	<input checked="" type="checkbox"/> Same as NEC Observations
<p>time but only lasted for a few days. I asked if the final drive is fixed and Casey stated that they hoped it would be fixed by the end of January as they were waiting for parts.</p> <p>2. I called the complainant on January 12, 2021 to get more details of the environmental concern. The complainant stated that she had recently moved into a residence close to the Wayne Wastewater Treatment plant and had concerns of the odors present. They had also raised concern with the dead flies that were present in the residence when moving in. I explained to her that there could be several explanations to the dead flies and that I had contacted the Wayne wastewater treatment plant to see if there were any upsets at the treatment plant. I explained that there was an issue with one of the clarifiers going down as the final drive went out of it in the end of September time frame and probably contributed to some of the increased odors in the area. The complainant thanked me for calling them and keeping me informed.</p>	


WHERE AT THE SITE IS THE PROBLEM?	<input checked="" type="checkbox"/> Same as NEC Observations
COMMENTS 1. Final clarifier	

OTHER PERTINENT DETAILS
COMMENTS I explained to the complainant that the Department didn't regulate indoor air quality and that they should contact Health and Human Services if there was a continued concern. I also explained what had been going on at the wastewater treatment plant and that it was in the process of being fixed.



Inspector

1/29/2021
Date



Compliance Unit Supervisor

1-29-2021
Date